

Measurements °C

Bx1	Max	42.4
	Min	36.8
	Average	41.5
Sp1		32.9
Sp2		31.9
Dt1	Bx1.Max - Sp1	9.5

Parameters

Emissivity	0.95
Refl. temp.	30 °C

Note

Sp1 and Sp2 are on a solid exterior wall with heat penetration to the interior defeating the efforts of the air conditioner.

05/04/2010 3:58:23 AM



FLIR0012.jpg

FLIR T600

55905584

05/04/2010 3:58:23 AM



FLIR0012.jpg

FLIR T600

55905584

Text annotations

--	--